

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION:	SALEM		
SYSTEM:	Reactivity Control (SF-1) – Control Rod Drive System (CRDS)		
TASK:	Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001		
TASK NUMBER:	N0010070101		
JPM NUMBER:	19-01 NRC Sim-c		
ALTERNATE PATH:	<input checked="" type="checkbox"/>	K/A NUMBER:	001 A2.11
APPLICABILITY:		IMPORTANCE FACTOR:	<u>4.4</u> <u>4.7</u>
EO <input type="checkbox"/>	RO <input checked="" type="checkbox"/>	STA <input type="checkbox"/>	SRO <input checked="" type="checkbox"/>
EVALUATION SETTING/METHOD:	Simulator / Perform		
REFERENCES:	S2.OP-ST.RCS-0001 Rev. 23 (checked 1-13-20)		
TOOLS AND EQUIPMENT:	None		
VALIDATED JPM COMPLETION TIME:	<u>15 Minutes</u>		
TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:	<u>N/A</u>		
Developed By:	R. Chan Instructor	Date:	1-13-20
Validated By:	Moore / Weidner SME or Instructor	Date:	1-13-20
Approved By:	N/A Training Department	Date:	
Approved By:	N/A Operations Department	Date:	
ACTUAL JPM COMPLETION TIME:			
ACTUAL TIME CRITICAL COMPLETION TIME:			
PERFORMED BY: _____			
GRADE:	<input type="checkbox"/> SAT	<input type="checkbox"/> UNSAT	
REASON, IF UNSATISFACTORY:			
EVALUATOR'S SIGNATURE:			DATE:

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

REVISION HISTORY

JPM NUMBER: 19-01 NRC Sim-c

Rev #	Date	Description	Validation Required
00	8-13-19	Modified JPM. Added Alternate Path for continuous rod motion when rod bank selected to Auto or Manual requiring operator to Manually trip the reactor. 001 K/A A2.11: Ability to (a) predict the impacts of the following malfunction or operation on the CRDS and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those malfunctions or operations: situations requiring a reactor trip	Yes

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

SIMULATOR SETUP INSTRUCTIONS

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)

TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

TASK NUMBER: 1150070501

SIMULATOR IC: IC-203

MALFUNCTIONS:

1. Reset the simulator to the above IC #.
2. Verify the following events on the Summary/ET Trigger Lists:

MALF ID #	Description	Delay Time	Initial Value	Ramp Time	Trigger	Severity
01	RD0045, Uncontrolled Rod Insert in Auto	N/A	N/A	N/A	ET-1	TRUE
02						

3. These malfunctions will simulate failure of rod control system when rods are selected to Auto or Manual (Alt Path) resulting in continuous rod insertion. The operator will mitigate the event by manually tripping the reactor.

OVERRIDES / REMOTES:

ID #	Description	Delay Time	Initial Value	Ramp Time	Trigger	Condition/Severity
01	KB433W1D, Rod Bank Selector Sw in Auto				ET-1	ON
02						
03						
04						

EVENT TRIGGERS:

ET#	Description	Command
1	KB433W1D, Rod bank Selector SW to Auto	

SPECIAL INSTRUCTIONS:

- Rod bank selector switch selected to **CBC position**
- **Ensure** ARPI screen is up on P-250.
- For efficiency, provide the procedures to the operators up front to allow time to read and review.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)

TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

TASK NUMBER: 1150070501

INITIAL CONDITIONS:

- Unit 2 is at 100% power BOL.
- No major equipment is out of service and no Tech Specs are active.
- The rod control system surveillance is in progress with the only remaining rod bank to test is Control Bank D.

INITIATING CUE:

- You are the Reactor Operator.
- The CRS directs you to complete the rod control system surveillance IAW S2.OP-ST.RCS-0001, Reactivity Control System Rod Control Assemblies.
- A Maintenance Technician is stationed at the Rod Control Power Cabinets (Relay Room)
- CRS directs that 15 steps of rod insertion will be performed to ensure each rod moves at least 10 steps.
- Pre-Test D bank rod positions were recorded and attached with your Cue Sheet.
- Notify the CRS when the testing is complete.
- Your evaluator will take care of all alarms not related to your task.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

Task Standard for Successful Completion:

1. Correctly performs rod control surveillance using approved procedure
2. Responds to continuous rod movement by manually tripping the reactor.

OPERATOR TRAINING PROGRAM

NAME: _____

JOB PERFORMANCE MEASURE

DATE: _____

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)

TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

* #	STEP NO.	STEP (Shaded area denotes Critical Step) (* Critical Step) (# Sequential Critical Step)	STANDARD (Bolded area identifies Task Standard)	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		<ul style="list-style-type: none"> ◆ ENSURE marked up copy of S2.OP-ST.RCS-0001 is open and marked up on console. ◆ Provide copy of OP-AP-300-1001, PWR Control Rod Movement Requirements. 			
		Operator reads and reviews procedures prior to start.	Operator reads P&Ls and reviews OP-AP-300-1001 prior to start		
	CUE:	Fill in the JPM Start Time when the student acknowledges the Initiating Cue. START TIME: _____			
	5.1.10	A. IF the reactor is critical, <u>THEN</u> ENSURE TAVG is within ±1°F of TREF.	Operator checks Tave/Tref recorder on 2RP4 and determines Tavg is within +/-1 F of Tref.		
*	5.1.10.B	B. PLACE Bank Selector Switch in the "CBD" position.	Operator rotates selector switch clockwise to the CBD position		

OPERATOR TRAINING PROGRAM

NAME: _____

JOB PERFORMANCE MEASURE

DATE: _____

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)

TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

* #	STEP NO.	STEP (Shaded area denotes Critical Step) (* Critical Step) (# Sequential Critical Step)	STANDARD (Bolded area identifies Task Standard)	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	5.1.10.C	C. ENSURE GRP. SELECT "B" lights are illuminated on Rod Control System Power Cabinets 21BD and 22BD.	Contacts Maint Technician at Power Cabinets. CUE: <i>Technician reports GRP SELECT 'B' lights are illuminated on Cabinets 21 BD and 22BD.</i>		
*	5.1.10.D	D. MANEUVER Control Bank D at least 10 steps in any one direction.	Operator inserts Control Bank D 15 steps.		
	5.1.10.E	E. ENSURE each rod in Control Bank D indicated rod movement of at least 10 steps.	Evaluator's Note: Operator may request to insert rods additional steps, <u>IF</u> so, just restate the request. Operator monitors rod position on P-250 and determines D bank rods all moved at least 10 steps. Optional CUE: <i>Reactor Engineer reports rods indicate 10 step movement.</i>		
*	5.1.10.F	F. RECORD CONTROL BANK D "Test Results" by initialing the SAT or UNSAT column using the Acceptance Criteria in Attachment 1, Rod Control Assembly Data.	Operator records test results as <u>SAT</u>.		

OPERATOR TRAINING PROGRAM
 JOB PERFORMANCE MEASURE

NAME: _____
 DATE: _____

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)
 TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

* #	STEP NO.	STEP (Shaded area denotes Critical Step) (* Critical Step) (# Sequential Critical Step)	STANDARD (Bolded area identifies Task Standard)	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	5.1.10.G	G. RESTORE Control Bank D to the pre-test position.	Operator withdraws Bank D to previous position (ARO)		
	5.1.11	ALIGN the Rod Control System as follows:			
		ALTERNATE PATH STARTS HERE:	Continuous rod movement when rod bank is selected to Auto or Manual		
	5.1.11.A	A. IF the reactor is critical, THEN ENSURE TAVG is within $\pm 1^{\circ}\text{F}$ of TREF.	Operator checks Tave/Tref recorder on 2RP4 and determines Tav _g is within 1 F of Tref.		
	5.1.11.B	B. IF Turbine Power is $\leq 15\%$, THEN PLACE Bank Selector Switch in the "MAN" position. Simulator Operator: ENSURE ET-1 is TRUE when rods selected to Auto. This will insert MALF: RD0045, Uncontrolled Rod Insertion in AUTO AND MANUAL.	N/A		

OPERATOR TRAINING PROGRAM
 JOB PERFORMANCE MEASURE

NAME: _____
 DATE: _____

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)
 TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

* #	STEP NO.	STEP (Shaded area denotes Critical Step) (* Critical Step) (# Sequential Critical Step)	STANDARD (Bolded area identifies Task Standard)	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*	5.1.11.C	C. IF Turbine Power is >15%, THEN PLACE Bank Selector Switch in the "AUTO" OR "MAN" position as directed by the SM/CRS.	<p>CUE: IF asked, <i>CRS directs rod bank selected to <u>AUTO</u>.</i></p> <p>Operator determines that Rx power is > 15% and rotates selector switch counterclockwise to the <u>AUTO</u> position.</p> <p>Operator announces that rods are stepping in and no runback in progress.</p> <p>CUE: IF operator recommends to CRS to place rods in Manual, <u>THEN</u> state; <i>understand placing rods to manual.</i></p> <p>Operator places rod bank switch to <u>Manual</u> and reports rod motion has NOT stopped.</p> <p>Operator Manually trips the Reactor.</p> <p>JPM Complete once Reactor is Tripped.</p>		
		<p><u>Examiner's Note:</u></p> <p>The operator may refer to S2.OP-AB.ROD-0003, Continuous Rod Motion and take the actions in the AB to manually trip the reactor.</p>			

OPERATOR TRAINING PROGRAM
 JOB PERFORMANCE MEASURE

NAME: _____
 DATE: _____

SYSTEM: Reactivity Control (SF-1) – Control Rod Drive System (CRDS)
 TASK: Perform Control Rod System Surveillance IAW S2.OP-ST.RCS-0001

* #	STEP NO.	STEP (Shaded area denotes Critical Step) (* Critical Step) (# Sequential Critical Step)	STANDARD (Bolded area identifies Task Standard)	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	CUE:	JPM is Complete RECORD the STOP TIME. STOP TIME: _____	Terminate the JPM when Reactor is tripped.		

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

JPM#: 19-01 NRC Sim-c

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- RC 1. Task description and number, JPM description and number are identified.
- RC 2. Knowledge and Abilities (K/A) references are included.
- RC 3. Performance location specified. (in-plant, control room, or simulator)
- RC 4. Initial setup conditions are identified.
- RC 5. Initiating and terminating cues are properly identified.
- RC 6. Task standards identified and verified by SME review.
- RC 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- RC 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. 23 Date 1-13-20
- RC 9. Pilot test the JPM:
 - a. verify cues both verbal and visual are free of conflict, and
 - b. ensure performance time is accurate.
- N/A 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- N/A 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor: R. Chan Date: 1-13-20

SME/Instructor: R. Moore Date: 1-13-20

SME/Instructor: Z. Weidner Date: 1-13-20

INITIAL CONDITIONS:

- Unit 2 is at 100% power BOL.
- No major equipment is out of service and no Tech Specs are active.
- The rod control system surveillance is in progress with the only remaining rod bank to test is Control Bank D.

INITIATING CUE:

- You are the Reactor Operator.
- The CRS directs you to complete the rod control system surveillance IAW S2.OP-ST.RCS-0001, Reactivity Control System Rod Control Assemblies.
- A Maintenance Technician is stationed at the Rod Control Power Cabinets (Relay Room)
- CRS directs that 15 steps of rod insertion will be performed to ensure each rod moves at least 10 steps.
- Pre-Test D bank rod positions were recorded and attached with your Cue Sheet.
- Notify the CRS when the testing is complete.
- Your evaluator will take care of all alarms not related to your task.