

Form 3.3-1 Scenario Outline

Facility:	<u>Salem</u>	Scenario #:	<u>1</u>
Scenario Source:	<u>20-01 ESG-1</u>	Op. Test #:	<u>21-01</u>
Examiners:	_____	Applicants/	_____
	_____	Operators:	_____
	_____		_____

Initial Conditions: Salem Unit 2 is at 100% power BOL

Turnover: The crew is directed to reduce power to 89% power at 10% per hour IAW S2.OP-IO.ZZ-0004 using boration, control rods and turbine load control in preparation for Main Turbine Valve testing.

Critical Tasks:

1. Close one Phase A isolation valve before transition out of TRIP-1
2. Transfer to Cold Leg Recirculation before receiving RWST Lo-Lo Alarm or ECCS pump cavitation

Event No.	Malf. No.	Event Type*	Event Description
1	N/A	ATC(R) BOP(R) CRS(N)	Load reduction to 89% at 10%/hr IAW IOP-4 for turbine valve testing
2	VC0087	BOP (C,MC) CRS (C)	24 Vacuum Pump trips
3	NI0193A	ATC(I,MC,R) CRS(I,TS)	2N41 fails HIGH
4	RC0002	ATC (C) CRS (C,TS)	RCS leak (20 gpm) inside containment
5	RC0002 RC0001A	ALL (M)	RCS leak worsens to 350 gpm/ Large Break LOCA (CT-2)
6	RP0108	ATC (I,MC) CRS (I)	Automatic SI fails to actuate
7	RP318M1	ALL(I,MC)	#2 ECAC fails to start.
8	VL0045 VL0046	ATC(C,MC) CRS(C)	Two Phase A valves fail to close (CT-1)
		ABs	AB.COND-1 → AB.NIS-1 → AB.RC-1
		EOPs	TRIP-1 → LOCA-1 → LOCA-3

* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor, (TS)Tech Spec, (MC)Manual Control

I. OBJECTIVES

- A. Given the order, perform a turbine load reduction in accordance with station procedures.
- B. Given indications of a loss of vacuum, perform actions as the nuclear control operator to RESPOND to the malfunction, IAW approved station procedures.
- C. Given indications of a loss of vacuum, DIRECT the response to the malfunction IAW approved station procedures.
- D. Given indications of a Power range nuclear instrument failure, perform actions as the nuclear control operator to RESPOND to the malfunction in accordance with approved station procedures.
- E. Given indications of a Power range nuclear instrument failure, DIRECT the response to the malfunction in accordance with approved station procedures.
- F. Given an RCS leak at power, respond to the event IAW approved station procedures.
- G. Given the indications of a reactor coolant system (RCS) malfunction or leak, perform actions as the nuclear control operator to RESPOND to the malfunction in accordance with the approved station procedures.
- H. Given the indications of a reactor coolant system (RCS) malfunction or leak, DIRECT the response to the malfunction in accordance with the approved station procedures.
- I. Given the order or indications of a reactor trip, perform actions as the nuclear control operator to RESPOND to the reactor trip in accordance with the approved station procedures.
- J. Given indication of a reactor trip, DIRECT the response to the reactor trip in accordance with the approved station procedures.
- K. Given the order or indications of a safety injection perform actions as the nuclear control operator to RESPOND to the safety injection in accordance with the approved station procedures.
- L. Given indication of a safety injection DIRECT the response to the safety injection in accordance with the approved station procedures.
- M. Given a safety injection has occurred and equipment has failed to start, START equipment that has failed to automatically start in accordance with station procedures.
- N. Given the order or indications of a loss of coolant accident (LOCA), complete actions as the nuclear control operator to PERFORM the immediate response to the LOCA in accordance with the approved station procedures.
- O. Given indication of a loss of coolant accident (LOCA), DIRECT the immediate response to the LOCA in accordance with the approved station procedures.
- P. Given the order or a loss of coolant accident (LOCA) and plant conditions to support cold leg recirculation, perform actions as the nuclear control operator to TRANSFER to cold leg recirculation in accordance with the approved station procedures.
- Q. Given a loss of coolant accident (LOCA) and plant conditions to support cold leg recirculation, DIRECT actions to transfer to cold leg recirculation in accordance with the approved station procedures.
- R. During performance of emergency operating procedures, monitor the critical safety function status trees in accordance the EOP in effect.

II. MAJOR EVENTS

1. Planned Load Reduction to 89% at 10%/hour
2. 24 Vacuum Pump trips
3. 2N41 Fails High (TS)
4. RCS Leak (20 gpm) (TS)
5. LBLOCA
6. Auto SI fails to actuate
7. #2 ECAC Fails to Start on SEC Signal
8. Two Phase A valves 2CV116, and 284 fail to close

III. SCENARIO SUMMARY

1. The crew assumes the watch at 100% power, EOL.
2. After assuming the watch, the crew will brief a planned load reduction to 89% at 10%/hour IAW **S2.OP-IO.ZZ-0004**, Power Operation, in preparation for Main Turbine Valve testing next shift.
3. After the power reduction has commenced, 24 condenser vacuum pump will trip. The crew will recognize that condenser backpressure is slowly rising and enter **S2.OP-AB.COND-0001**, Loss of Condenser Vacuum. The crew will start all available vacuum pumps and stabilize condenser back pressure. The 25AR25 will fail to open and the operator will manually open from control room.
4. After the crew addresses the vacuum pump trip, 2N41 Power Range channel will fail high. The operator will respond by placing rod control in Manual. The crew will enter **S2.OP-AB.NIS-0001**, NIS Malfunction, and perform actions to remove channel from service. The CRS will evaluate Tech Specs.
5. Once actions for 2N41 Power Range channel are addressed, a RCS leak (20 gpm) will occur resulting in lowering PZR level and rising counts on the 2R11A containment radiation monitor. The CRS will enter **S2.OP-AB.RC-0001**, **RCS Leak**, and adjust Charging flow to stabilize PZR level. The CRS will evaluate TS and enter TS 3.4.7.2.b, Action b. Once TS has been evaluated, the RCS leak will worsen to 350 gpm. The crew will take CAS actions in S2.OP-AB.RC-0001 and manually trip the reactor, at which time the RCS leak will escalate into a Large Break LOCA.
6. Immediately following the Rx Trip a malfunction will prevent Auto Safety Injection from actuating. The crew will respond by manually initiating SI. The crew will enter **EOP-TRIP-1**, Reactor Trip or Safety Injection.
7. While in EOP-TRIP-1, the crew will recognize that #2 ECAC failed to start on SEC signal. The crew will block and reset 2C SEC, then manually start #2 ECAC, additionally two Phase A valves will fail to close and the crew will take action to close at least one valve in the penetration. **[Critical Task #1]**.
8. The crew will perform diagnostics in EOP-TRIP-1 and eventually transition to **EOP-LOCA-1**, Loss of Reactor Coolant and **EOP-LOCA-3**, Transfer to Cold leg recirculation. While in LOCA-3

they will establish cold leg recirculation. [**Critical Task #2 – this CT includes time critical operator actions**].

9. The scenario can be terminated when the crew reduces ECCS to one train, stops all ECCS pumps taking suction from the RWST if the Lo-Lo level alarm is received, or by direction from Lead Examiner.

IV. INITIAL CONDITIONS

___ IC-240

PREP FOR TRAINING (i.e. computer setpoints, procedures, bezel covers ,tagged equipment)

<i>Initial</i>	Description
___ 1	2VC1and 2VC4 C/T
___ 2	RCPs (SELF CHECK)
___ 3	RTBs (SELF CHECK)
___ 4	21-24MS167s (SELF CHECK)
___ 5	500 KV SWYD (SELF CHECK)
___ 6	21 and 22 SGFP Trip (SELF CHECK)
___ 7	Suggested Protected Equipment: <ul style="list-style-type: none">▪ none
___ 8	Complete Attachment 2 “Simulator Ready-for-Training/Examination Checklist.”

Note: Tables with blue headings may be populated by external program, do not change column name without consulting Simulator Support group

EVENT TRIGGERS:

Initial	ET #	Description
	1	EVENT ACTION: kck05anz //25AR25 25 VACUUM PUMP-CONDENSER COMMAND: DMF VL0440 PURPOSE: <update as needed>
	2	EVENT ACTION: MONP254 < 10. //CONT ROD BANK C < 10 (RX TRIP) COMMAND: PURPOSE: <update as needed>
	3	EVENT ACTION: kb116tcb //2CV116 SEAL W TO VCT CLOSE COMMAND: DMF VL0045 PURPOSE: <update as needed>
	4	EVENT ACTION: kb117tcb //2CV284 SEAL W TO VCT CLOSE COMMAND: DMF VL0046 PURPOSE: <update as needed>
	5	EVENT ACTION: KCK02PBZ //22 VACUUM PUMP-START COMMAND: PURPOSE: <update as needed>

MALFUNCTIONS:

SELF-CHECK	Description	Delay Time	Initial Value	Ramp Time	Trigger	Severity
___ 01	VC0087C TRIP OF VACUUM PUMP 24	N/A	N/A	N/A	RT-1	
___ 02	VC0087A TRIP OF VACUUM PUMP 22	00:00:15	N/A	N/A	ET-5	
___ 03	VL0440 25AR25 Fails to Position (0-100%)	N/A	N/A	N/A	N/A	0
___ 04	NI0193A PR CH N41 FAILS HI/LO	N/A	N/A	N/A	RT-2	150
___ 05	RC0002 RCS LEAK INTO CONTAINMENT (equiv to 0-4 inches)	N/A	N/A	N/A	RT-3	20
___ 06	RC0001A RCS RUPTURE OF RC LOOP 21	N/A	N/A	N/A	ET-2	
___ 07	RP0108 FAILURE OF AUTOMATIC SI	N/A	N/A	N/A	N/A	
___ 08	RP318M1 EMER Contrl Air Compressor Fails to Start on SEC	N/A	N/A	N/A	N/A	
___ 09	VL0045 2CV116 Fails to Position (0-100%)	N/A	N/A	N/A	N/A	100
___ 10	VL0046 2CV284 Fails to Position (0-100%)	N/A	N/A	N/A	N/A	100

REMOTES:

SELF-CHECK	Description	Delay Time	Initial Value	Ramp Time	Trigger	Condition
------------	-------------	------------	---------------	-----------	---------	-----------

--	--	--	--	--	--	--

OVERRIDES:

SELF-CHECK	Description	Delay Time	Initial Value	Ramp Time	Trigger	Condition/Severity

OTHER CONDITIONS:

	Description
--	-------------

- ___ 1. None

V. SEQUENCE OF EVENTS

- A. State shift job assignments.
- B. Hold a shift briefing, detailing instruction to the shift: (provide crew members a copy of the shift turnover sheet)
- C. Inform the crew “The simulator is running. You may commence panel walkdowns at this time. SM please inform me when your crew is ready to assume the shift”.
- D. Allow sufficient time for panel walk-downs. When informed by the SM that the crew is ready to assume the shift, ensure the simulator is cleared of unauthorized personnel.

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
1. Power Reduction to 89%			
	CRS briefs crew on power reduction to 89% at 10%/hour IAW S2.OP-IO.ZZ-0004, Section 4.3 Power Reduction.		
<p>Note: Turnover states to add 120 gal of boric acid, Crew may decide to do multiple batches or 120 gal at a slow rate.</p>	RO briefs boration plan for load reduction.		
	PO briefs turbine load control plan.		
<p>RO will most likely use boration “hard card” Attachment 3 of S2.OP-SO.CVC-0006</p>	<p>RO initiates boration IAW S2.OP-SO.CVC-0006.</p> <ul style="list-style-type: none"> • PRESS Make up mode STOP • ADJUST 2CV172 boric acid flow setpoint to desired value • SET boric acid flow register to desired gallons • PRESS Makeup control mode BORATE pushbutton • PRESS Makeup control mode START • ENSURE boric acid flow register indicates flow 		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
<p>PO will most likely use Routine Load Reduction “hard card” Attachment 3 of S2.OP-SO.TRB-0002</p> <p>Note: PO must toggle ramp rates from Per minute to per hour</p>	<p>PO initiates turbine load reduction IAW S2.OP-SO.TRB-0002, Turbine Generator Shutdown Operation.</p> <ul style="list-style-type: none"> • ENSURE Main Turb data display on Plant computer • ADJUST turbine ramp rate for TIP control to 10%/hr • ADJUST setter to 89% • Select GO • ENSURE setter – actual and Reference displays are updating 		
	RO monitors Tavg and control rods for proper response.		
Proceed to next event by direction from Lead Examiner.			
<p>Examiner’s Note: The crew may at any time stop the load reduction to respond to the next events.</p>			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
2. 24 Vacuum Pump Trips:			
Simulator Operator: At direction from Lead Evaluator insert RT-1 . This will trip 24 vacuum pump: VC0087C, Trip of Vacuum Pump 24			
	PO reports unexpected trip of 24 Vacuum Pump.		
	CRS enters S2.OP-AB.COND-0001, Loss of Condenser Vacuum.		
	PO initiates Attachment 1 CAS.		
	CRS dispatches operator to perform Attachment 2, Loss of Vacuum Local Checks.		
Role Play: When dispatched to perform Attachment 2, THEN after 2-5 minutes report the following: <i>I've completed Attachment 2 and have found no abnormal conditions except for the vacuum pump breaker being tripped open on 22 and 24 vacuum pumps.</i>			
	PO reports 24 Vacuum pump is stopped and the 24AR25 is closed.		
	PO reports condenser backpressure is rising rapidly.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
22 Vacuum Pump trips following start:	PO reports rising backpressure is not attributed to CW System malfunctions.		
	PO starts all available (22 and 25) vacuum pumps.		
Simulator Operator: Ensure ET-2 is TRUE IF 22 Vacuum pump is started. This will cause the pump to trip following start.			
25AR25 fails to open following start of 25 Vacuum Pump:			
	IF 22 Vacuum Pump is started, the PO reports that the pump started then tripped seconds later.		
Role Play: IF requested to check local indications at the Vacuum Pump, THEN report that <i>the local gauge reading is within the normal band and all other parameters are within their normal bands.</i>	PO reports that 25 Vacuum Pump started but the 25AR25 failed to open.		
	PO manually opens 25AR25.		
Proceed to next event at direction from Lead Examiner.	PO reports that condenser back pressure is improving.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments	
<p>3. 2N41 Power Range Channel fails high</p> <p>Simulator Operator: Enter RT-2 on direction of Lead Evaluator.</p> <p>MALF: NI0193A PR CH41 Fails High Severity: 150</p>				
	RO reports rods stepping in and no runback in progress			
	RO places rod control in Manual			
	CRS enters S2.OP-AB.NIS-0001, NIS Malfunction.			
	<p>Evaluator's Note: The crew may enter S2.OP-AB.ROD-0003 which will transition you to AB.NIS-0001</p>			
		RO reports rod control is in Manual		
PO reports no turbine load change in progress				
RO reports that 2N41 channel is failed high				
<p>RO reports the following OHA alarms are in:</p> <ul style="list-style-type: none"> ▪ E-15 PR HI RNG FLUX HI ▪ E-31 PR OVRPWR ROD STOP ▪ E-39 PR CH DEV ▪ E-47 PR NEUT FLUX RATE HI 				

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	CRS directs PO to remove PR channel from service IAW S2.OP-SO.RPS-0001, NI Channel Trip/Restoration		
<p>Evaluator's Note: At the direction of the Lead Evaluator, performing removing of 2N41 from service is optional.</p> <p>Performing these steps takes about <u>10 minutes</u>.</p>			
Placing 2N41 in Tripped Condition IAW S2.OP-SO.RPS-0001, Steps 4.1.1 to 4.1.5:			
	PO ensures that tripping of associated bistable(s) will NOT result in an ESF OR RPS actuation		
	PO ensures 2N41 Channel is NOT selected on NIS Recorder 2NR45		
	PO ensures Rod Control is in Manual		
	CRS enters T/S 3.3.1.1, Actions 2 and 6 (72 hours) Reactor Trip System Instrumentation for 2N41		
	At NI Rack No. 81, PO performs the following:		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	PO places DETECTOR CURRENT COMPARATOR, UPPER SECTION, switch in PRN41 position AND ENSURE the following: ___ CHANNEL DEFEAT lamp illuminates. ___ OHA E-38, UPPER SECT DEV ABV 50% PWR, clears. <u>Note</u> : E-38 was not in.		
	PO places DETECTOR CURRENT COMPARATOR, LOWER SECTION, switch in PRN41 position AND ENSURE the following: ___ CHANNEL DEFEAT lamp illuminates. ___ OHA E-46, LOWER SECT DEV ABV 50% PWR, clears. <u>Note</u> E-46 was not in.		
	PO places POWER MISMATCH BYPASS switch in BYPASS PR N41. (Defeats input to Rod Control)		
	PO places ROD STOP BYPASS switch in BYPASS PR N41 AND ENSURE the following: ___ 2RP4 - OVER POWER ROD STOP MANUAL BYPASS, CH I is illuminated. ___ OHA E-31, PR OVERPWR ROD STOP, is clear		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	PO places COMPARATOR CHANNEL DEFEAT switch in N41 AND ENSURE the following: ___ COMPARATOR DEFEAT lamp is illuminated. ___ OHA E-39, PR CH DEV, is clear		
<p>Evaluator's Note: After Step 4.1.5 is complete Maintenance support is needed to complete the rest of the procedure for tripping bistables.</p> <p>Rod control can be placed in Auto at this time if the CRS directs. Leaving Rods in Manual has no effect to the outcome of the scenario.</p>			
	CRS directs Maintenance to remove 2N41 channel from service IAW S2.OP-SO.RPS-0001.		
	RO withdraws rods as required to maintain band prescribed.		
	CRS may elect to restore rod control to Auto <u>or</u> leave in Manual until the bistables are tripped.		
Proceed to next event after rods are withdrawn to ARO or by direction from Lead Evaluator.			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
4. RCS Leak (20 gpm)			
Simulator Operator: Insert RT-3 by direction from Lead Examiner.			
RC0002, RCS Leakage			
Value = 20			
Ramp = None			
	RO reports counts on the 2R11A containment radiation monitor is rising.		
	RO reports PZR level is lowering and/or RCS pressure is lowering.		
	RO reports RCS leak inside containment.		
	RO determines RCS leak rate.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	RO reports PZR level is lowering.		
	RO swaps to a centrifugal charging pump in service. <ul style="list-style-type: none"> • CLOSE 2CV55 CHARG FLOW CONTR VALVE • START 21 or 22 CHG pp • LOWER 23 Chg PP speed while ADJUSTING 2CV55 • STOP 23 Chg pp • ADJUST 2CV55 to control PZR lvl • ENSURE seal injection flow 6-12 gpm/pump not to exceed 40 total 		
	CRS directs RO to adjust charging flow to stabilize PZR level.		
	RO adjusts charging flow to stabilize PZR level and then determines RCS leak rate.		
TS evaluation #2:	CRS enters: <ul style="list-style-type: none"> • TS 3.4.7.2.b (1 gpm unidentified leakage), action b (reduce leakage rate to within limits within 4 hours or be in Hot Standby) 		
Proceed on to next event after TS has been evaluated or by direction from the Lead Examiner			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
5. RCS leak worsens to 350 gpm and Large Break LOCA (Major Transient):			
Simulator Operator: Modify RT-3 to 350 at the direction of the Lead Examiner. RC0002, RCS Leakage Value = 350 Ramp = None			
	RO reports PZR level is lowering rapidly.		
	RO attempts to maintain PZR level by adjusting charging flow.		
	RO reports RCS leak rate exceeds make up capability.		
	CRS implements the Attachment 1 CAS action and briefs the RO to Trip the Reactor and actuate Safety Injection.		
	RO trips the reactor and actuates SI.		
Simulator Operator: Ensure ET-2 is TRUE following Rx Trip. This will insert LBLOCA malfunction. RC0001A, RCS rupture on RC loop 21			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
6. Auto SI fails to actuate on both trains:			
	RO may report SI failed to Auto actuate (depending on where RCS pressure is at during time SI is manually actuated)		
	RO manually actuates SI on one Train and verifies the other train actuated.		
	RO continues Immediate Actions of TRIP-1: <ul style="list-style-type: none"> ▪ Reports the Main Turbine is tripped and backs up Main Turbine trip. ▪ Reports all 4KV vital busses energized. ▪ Reports SI has been initiated. 		
	CRS and RO verify Immediate Actions complete.		
	CRS directs initiation of the following EOP-TRIP-1 CAS actions when RCS pressure meets the criteria: <ul style="list-style-type: none"> • Stops RCPs (1240(1350 adverse) psig) • Close Charging Mini-flows (1500 psig) 		
	PO reports ALL Vital Buses are energized.		
	PO reports SEC loading for 2B and 2C vital bus is NOT complete.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
7. # 2 ECAC fails to start on SEC signal			
	PO reports # 2 ECAC failed to start.		
	PO blocks and resets 2C SEC.		
	RO Starts #2 ECAC.		
	PO throttles AFW flow to no less than 22E4lbm/hr while SG NR levels remain <9%. (15% adverse)		
	RO reports containment pressure has NOT remained <15 psig.		
	RO reports Phase B and Spray actuation Auto initiated.		
	RO reports 21 and 22 CS pumps are running.		
	RO reports MSLI Auto initiated.		
	RO reports all valves groups in Table B are in the safeguards positions.		
	RO Stops all RCPs.		
	PO reports 2RP4 indicates High-High Containment Pressure.		
	RO reports both trains of MSLI has actuated.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	PO reports all valves in Table D are closed.		
	RO reports 2 CCW pumps are running.		
	RO reports both CCW HXs are in Auto.		
	RO reports 2CC131 (Thermal Barrier Return) is closed.		
	RO reports Phase B has occurred and 2CC131 should not be opened.		
	CRS notifies WCC to monitor Spent Fuel Pool temperature and level.		
	RO reports RWST Lo Level Alarm has not actuated (this is a CAS step)		
	PO reports 2CV116 and 284 in Table E are NOT in the safeguards positions.		
	Critical task #1 - RO closes the 2CV116 and 284 from the 2CC2 console pushbuttons		
Critical Task-1 (CT-11): Close at least one valve on each phase A penetration before transition out of EOP-TRIP-1, Reactor Trip or Safety Injection. SAT _____ UNSAT _____			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	RO reports 21 and 22 CA330s are closed.		
	RO reports CAV is in Accident Pressurize Mode.		
	RO reports CAV is not in Maintenance Mode Alignment		
	RO reports two switchgear fans and one switchgear exhaust fan are running		
	RO reports Charging, SI pump and RHR pump flows are consistent with RCS pressure.		
	PO maintains total AFW flow >22E4 lbm/hr until at least one SG NR level is > 9% (15% adverse), then maintains SG NR levels between 19% and 33%.		
Examiner's Note: Based on the pace of the crew, they may perform the following CAS steps sooner or later in EOP-TRIP-1.			
	RO closes charging pump mini flows IAW TRIP-1 CAS when RCS pressure is < 1500 psig with BIT flow established. [TRIP-1 CAS]		
	RO stops RCPs IAW TRIP-1 CAS when RCS pressure is <1240(1350 adverse) psig with ECCS flow established. [TRIP-1 CAS]		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments	
Examiner's Note: SG pressure could be lowering slowly based on the break flow from the LBLOCA.	RO reports RCP status, and CRS determines whether a MSLI for temperature control is required.			
	RO reports PZR spray valves response are normal.			
	RO reports RCS pressure < 1240(1350 adverse) psig and ECCS flow established.			
	PO reports NO indications of a Faulted SG exist.			
	PO reports NO indications of a SGTR exist.			
	RO reports two or more channels in Table J are NOT indicating normal on the P250 computer OR reports Containment Pressure > 4 psig.			
	Evaluator's Note: IF RWST low level (15.2 ft.) is reached during TRIP-1, THEN go to <u>page 27</u> for LOCA-3 steps.			
EOP-LOCA-1 steps here:				
	CRS transitions to 2-EOP-LOCA-1, Loss of Reactor Coolant.			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
Examiner's Note: During LOCA-1, the crew will reach the low RWST alarm (15.2 feet) and then transition to EOP-LOCA-3.			
Examiners Note: A CFST PURPLE Path on Thermal Shock may exist during LOCA-1, if so, the crew will enter and exit FRTS-1 with no actions performed.			
	RO reports all RCPs are stopped.		
	PO reports no indications of faulted SGs.		
	PO maintains total AFW flow >22E4 lbm/hr until at least one SG NR level is > 9% (15% adverse), then maintains SG NR levels between 19% and 33%.		
	RO resets Phase A.		
	RO opens 21 and 22 CA330s.		
	RO resets SG B/D Sample Isolation Bypass		
	RO opens 21 thru 24 SS94s (SG B/D Sample Valves)		
	PO reports ALL secondary radiation monitors in Table B are indicating Normal.		
	RO reports both PZR PORVs are Closed and Block valves are Open.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	RO reports subcooling is NOT greater than 0 F.		
	RO reports both CS Pumps are running.		
	RO resets both trains of SI.		
	PO resets each SECs.		
	RO reports RCS pressure is not greater than 300 psig.		
	Crew stops unloaded EDG's		
	Crew determines LOCA 5 and 6 transition not required and consult with the TSC		
	Crew will now loop back around to Step 11 or transition to LOCA-3.		
	CRS enters 2-EOP-FRTS-1, Response to Imminent Pressurized Thermal Shock Conditions.		
	STA verifies procedure transition.		
	RO reports RCS pressure is < 420 psig and RHR flow is at least 300 gpm.		
	CRS returns to procedure in effect (LOCA-1).		

FRTS-1 steps here:

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
Record Time RWST Lo Level Alarms Actuated: Time: ____:____:____			
8. Transfer to Cold Leg Recirculation (EOP-LOCA-3) Evaluator's Note: A predetermined Critical Task which includes Time Critical Operator Actions			
RO reports Containment Sump CH A (B) Level > 62% is illuminated.			
RO depresses SUMP AUTO ARMED PB for 21 and 22 SJ44s.			
PO removes lockouts from 2SJ67, 2SJ68, 2SJ69.			
RO reports 21 and 22 SJ44s open.			
RO reports both RHR pumps running.			
RO closes 2SJ69.			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
Mark time 2SJ69 close PB depressed. _____ : _____ : _____ ≤ 3.7 mins after RWST lo level			
	RO verifies or performs SI reset actions.		
	RO resets SECs and 230V MCCs.		
	RO stops 22 Containment Spray Pump.		
Mark time 22 CS pump stopped. _____ : _____ : _____ ≤ 5.5 mins after RWST Lo Level			
	RO closes 21 and 22 RH19s.		
	RO stops 23 charging pump.		
	CRS goes to Step 11 based on all Vital Buses energized.		
	RO reports 3 SW pumps running.		
	PO reports both CCHXs are in service <u>OR</u> being restored to service per EOP-APPX-1.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
	RO reports that 22 CS pump is NOT running.		
	RO reports that 21 and 22 CC16 are open.		
	RO performs the following: <ul style="list-style-type: none"> ▪ Closes 2SJ67 and 2SJ68. ▪ Reports 2RH1 and 2RH2 are closed. 		
	RO opens 21 and 22 SJ45s.		
	RO reports 21 and 22 SJ113's are open.		
	RO reports 21 and 22 SI pumps <u>and</u> 21 and 22 Charging pumps are running.		
<div style="border: 1px solid black; padding: 5px;"> <p>Mark time ECCS pumps verified in operation.</p> <p>____:____:____</p> <p>≤ 11.2 mins after RWST Lo Level</p> </div>			
	PO removes lockout for 2SJ30		
	RO closes 2SJ30, 2SJ1, and 2SJ2		
	RO places 21RH29 and 22RH29 in MANUAL and reports both valves are closed.		

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
<p>Critical Task-2 (CT-36): Transfer to Cold Leg Recirculation before RWST Lo-Lo Level (1.2 feet) is reached or ECCS pump cavitation. This CT also includes accomplishing operator time critical actions as specified below:</p> <p>Time Critical Operator Actions:</p> <p>Transfer to Cold Leg Recirculation such that at least one train of ECCS is in operation in the recirculation mode within the following time frames:</p> <ol style="list-style-type: none"> 1. From RWST lo level alarm to initiating closed on 2SJ69 - ≤ 3.7 minutes 2. From RWST lo level alarm to one containment spray pump stop ≤ 5.5 minutes 3. From RWST lo level alarm to switchover completion (includes restarting ECCS pumps if stopped on RWST lo-lo level) ≤ 11.2 minutes. <p>SAT _____ UNSAT _____</p>			

Evaluator/Instructor Activity	Expected Plant/Student Response	SBT LOG	Comments
<u>Terminate</u> scenario when the crew initiates close or verifies closed for RH29s <u>or</u> at Lead Evaluator direction.			

VI. SCENARIO REFERENCES

- A. Alarm Response Procedures (various)
- B. Technical Specifications
- C. Emergency Plan (ECG)
- D. S2.OP-AB.COND-0001, Loss of Condenser Vacuum
- E. S2.OP-AB.ROD-0003, Continuous Rod Motion
- F. S2.OP-AB.NIS-0001, Nuclear Instrumentation System Malfunctions
- G. S2.OP-AB.RC-0001, RCS Leak
- H. 2-EOP-TRIP-1, Reactor Trip or Safety Injection
- I. 2-EOP-LOCA-1, Loss of Reactor Coolant
- J. 2-EOP-LOCA-3, Transfer to Cold leg recirculation

MODE: 1 POWER: 100% RCS BORON: 967 ppm MWe 1220

SHUTDOWN SAFETY SYSTEM STATUS (5, 6 & DEFUELED):

NA

REACTIVITY PARAMETERS:

- Rx Plan: To lower Rx power to 89% at 10%/hour add 120 gallons of boric acid along with inserting control rods to maintain Tav_g on program. Reactor Engineering directs the crew to perform a boration first. Expect D bank at 193 steps when load reduction is complete.

MOST LIMITING LCO AND DATE/TIME OF EXPIRATION:

- None

EVOLUTIONS/PROCEDURES/SURVEILLANCES IN PROGRESS:

- Load reduction to 89% at 10%/hour in preparation for Main Turbine valve testing.

ABNORMAL PLANT CONFIGURATIONS:

- None

CONTROL ROOM:

- Hope Creek and Salem 1 are at 100% power.

PRIMARY:

- none

SECONDARY:

- Heating Steam is aligned to Unit 1
- Polisher is in service
- Blowdown is 35K per loop to 23 Condenser / Flashtank

RADWASTE:

- No discharges in progress

CIRCULATING WATER/SERVICE WATER:

ATTACHMENT 2

SIMULATOR READY-FOR-TRAINING CHECKLIST

1. Verify simulator is in "TRAIN" Load
2. Simulator is in RUN
3. Overhead Annunciator Horns ON
4. All required computer terminals in operation
5. Simulator clocks synchronized
6. All tagged equipment properly secured and documented
7. TSAS Status Board up-to-date
8. Shift manning sheet available
9. Procedures in progress open and signed-off to proper step
10. All OHA lamps operating (OHA Test) and burned out lamps replaced
11. Required chart recorders advanced and ON (proper paper installed)
12. All printers have adequate paper AND functional ribbon
13. Required procedures clean
14. Multiple color procedure pens available
15. Required keys available
16. Simulator cleared of unauthorized material/personnel
17. All charts advanced to clean traces and chart recorders are on.
18. Rod step counters correct (channel check) and reset as necessary
19. Exam security set for simulator
20. Ensure a current RCS Leak Rate Worksheet is placed by Aux Alarm Typewriter
With Baseline Data filled out
21. Shift logs available if required
22. Recording Media available (if applicable)
23. Ensure ECG classification is correct
24. Reference verification performed with required documents available
25. Verify phones disconnected from plant after drill.
26. Verify EGC paperwork is marked "Training Use Only" and is current revision.
27. Ensure sufficient copies of EGC paperwork are available.

ATTACHMENT 3 CRITICAL TASK METHODOLOGY

In reviewing each proposed CT, the examination team assesses the task to ensure, that it is essential to safety. A task is essential to safety if, in the judgment of the examination team, the improper performance or omission of this task by a licensee will result in direct adverse consequences or in significant degradation in the mitigative capability of the plant.

The examination team determines if an automatically actuated plant system would have been required to mitigate the consequences of an individual's incorrect performance. If incorrect performance of a task by an individual necessitates the crew taking compensatory action that would complicate the event mitigation strategy, the task is safety significant.

- I. Examples of CTs involving essential safety actions include those for which operation or correct performance prevents...
 - degradation of any barrier to fission product release
 - degraded emergency core cooling system (ECCS) or emergency power capacity
 - a violation of a safety limit
 - a violation of the facility license condition
 - incorrect reactivity control (such as failure to initiate Emergency Boration or Standby Liquid Control, or manually insert control rods)
 - a significant reduction of safety margin beyond that irreparably introduced by the scenario
- II. Examples of CTs involving essential safety actions include those for which a crew demonstrates the ability to...
 - Effectively direct or manipulate engineered safety feature (ESF) controls that would prevent any condition described in the previous paragraph.
 - Recognize a failure or an incorrect automatic actuation of an ESF system or component.
 - Take one or more actions that would prevent a challenge to plant safety.
 - Prevent inappropriate actions that create a challenge to plant safety (such as an unintentional Reactor Protection System (RPS) or ESF actuation).

**ATTACHMENT 4
SIMULATOR SCENARIO REVIEW CHECKLIST**

SCENARIO IDENTIFIER: 21-01 NRC Scenario #1 REVIEWER: K. Hantho

Initials	Qualitative Attributes
K	1. The scenario has clearly stated objectives in the scenario.
K	2. The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue crew into expected events.
K	3. The scenario consists mostly of related events.
K	4. Each event description consists of: <ul style="list-style-type: none">• the point in the scenario when it is to be initiated• the malfunction(s) that are entered to initiate the event• the symptoms/cues that will be visible to the crew• the expected operator actions (by shift position)• the event termination point
K	5. No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.
K	6. The events are valid with regard to physics and thermodynamics.
K	7. Sequencing/timing of events is reasonable, and allows for the examination team to obtain complete evaluation results commensurate with the scenario objectives.
K	8. The simulator modeling is not altered.
K	9. All crew competencies can be evaluated.
K	10. The scenario has been validated.
NA	11. If the sampling plan indicates that the scenario was used for training during the requalification cycle, evaluate the need to modify or replace the scenario.
K	12. ESG-PSA Evaluation Form is completed for the scenario at the applicable facility.

**ATTACHMENT 5
ESG CRITICAL TASKS**

20-01 NRC Scenario #1

CT-1 (CT-11)

Critical Task

Close containment isolation valves such that at least one valve is closed on each Phase A penetration before transition out of TRIP-1.

Safety Significance

The containment isolation system preserves the ability of the containment boundary to minimize the release of fission products following a LOCA or a fuel handling accident within the containment. The Phase A containment isolation signal serves to actuate the containment isolation system following a LOCA. The Phase A containment isolation signal actuates all power operated valves that are not required to be open for the operation of essential equipment during an accident and that can be immediately closed without increasing the potential for damage to the containment equipment.

Cues:

- Indication and/or annunciation that SI is actuated

AND

- One or more of the following:
 - Absence of annunciation that Phase A isolation is actuated
 - Absence of closed valve position indication on all (both) containment isolation valves on one or more Phase A penetrations
 - Open valve position indication on all (both) containment isolation valves on one or more Phase A penetrations
 - ESF system status lamps show that all (both) containment isolation valves on one or more Phase A penetrations are not closed

Measurable Performance Indicator

Manipulation of controls as required to close at least one containment isolation valve on each Phase A penetration

- Closed valve position indication for at least one containment isolation valve on each Phase A penetration

Feedback

- ESF system status lamps show that at least one containment isolation valve is closed on each Phase A penetration

CT-2 (CT-36)

Critical Task

Transfer to cold leg recirculation before receiving the RWST Lo-Lo alarm or cavitation to ECCS Pumps (this CT includes time critical operator actions per OP-SA-102-106-F1)

Safety Significance

Failure to transfer to cold leg recirculation before the RWST inventory is totally depleted results in the loss of all pumped safety injection and containment spray when the RWST empties.

Cues:

- Indication and/or annunciation that safety injection is actuated

AND

- Indication and/or annunciation that RWST level is at or below the Low Level Alarm

AND

- Indication that containment sump level is at or above the minimum level (62%) required for transfer to cold leg recirculation

Measurable Performance Indicator

Manipulation of controls as required to transfer to cold leg recirculation and establish ECCS recirculation flow that at least meets the assumptions of the plant-specific LOCA analyses:

- Valve position indication that the cold leg recirculation flow path is established
- Control switch indication that the circuit breakers or contactors for the low-head injection pumps (and other ECCS injection pumps as necessary) are closed
- These operator time critical actions are accomplished as follows from the time from RWST Lo Level:
 - Initiating close on 2SJ69 ≤ 3.7 minutes
 - Stopping one Containment Spray Pump ≤ 5.5 minutes
 - Switch over to recirculation complete ≤ 11.2 minutes

Feedback

- Flow indication of the recirculation of containment sump water through the RHR heat exchangers and into the RCS

ATTACHMENT 6

ESG – PSA RELATIONSHIP EVALUATION

EVENTS LEADING TO CORE DAMAGE

<u>Y/N</u>	<u>Event</u>	<u>Y/N</u>	<u>Event</u>
<u>N</u>	TRANSIENTS with PCS Unavailable	<u>N</u>	Loss of Service Water
<u>N</u>	Steam Generator Tube Rupture	<u>N</u>	Loss of CCW
<u>N</u>	Loss of Offsite Power	<u>N</u>	Loss of Control Air
<u>N</u>	Loss of Switchgear and Pen Area Ventilation	<u>N</u>	Station Black Out
<u>Y</u>	LOCA		

COMPONENT/TRAIN/SYSTEM UNAVAILABILITY THAT INCREASES CORE DAMAGE FREQUENCY

<u>Y/N</u>	<u>COMPONENT, SYSTEM, OR TRAIN</u>	<u>Y/N</u>	<u>COMPONENT, SYSTEM, OR TRAIN</u>
<u>N</u>	Containment Sump Strainers	<u>N</u>	Gas Turbine
<u>N</u>	SSWS Valves to Turbine Generator Area	<u>N</u>	Any Diesel Generator
<u>N</u>	RHR Suction Line valves from Hot Leg	<u>N</u>	Auxiliary Feed Pump
<u>N</u>	CVCS Letdown line Control and Isolation Valves	<u>N</u>	SBO Air Compressor

OPERATOR ACTIONS IMPORTANT IN PREVENTING CORE DAMAGE

<u>Y/N</u>	<u>OPERATOR ACTION</u>
<u>N</u>	Restore AC power during SBO
<u>N</u>	Connect to gas turbine
<u>N</u>	Trip Reactor and RCPs after loss of component cooling system
<u>Y</u>	Re-align RHR system for re-circulation
<u>N</u>	Un-isolate the available CCW Heat Exchanger
<u>N</u>	Isolate the CVCS letdown path and transfer charging suction to RWST
<u>N</u>	Cooldown the RCS and depressurize the system
<u>N</u>	Isolate the affected Steam Generator that has the tube rupture(s)
<u>N</u>	Early depressurize the RCS
<u>N</u>	Initiate feed and bleed

SCAN OF SIGNED SCENARIO COVER SHEET