

INDEX

DEFINITIONS

<u>SECTION</u>	<u>PAGE</u>
<u>1.0 DEFINITIONS</u>	
DEFINED TERMS.....	1-1
ACTION.....	1-1
AXIAL FLUX DIFFERENCE ..	1-1
CHANNEL CALIBRATION ..	1-1
CHANNEL CHECK	1-1
CHANNEL FUNCTIONAL TEST	1-1
CONTAINMENT INTEGRITY	1-2
CORE ALTERATION	1-2
CORE OPERATING LIMITS REPORT	1-2
DOSE EQUIVALENT I-131 ..	1-2
DOSE EQUIVALENT XE-133	1-3
ENGINEERED SAFETY FEATURE RESPONSE TIME	1-3
FREQUENCY NOTATION . . .	1-3
FULLY WITHDRAWN	1-3
GASEOUS RADWASTE TREATMENT SYSTEM	1-3
IDENTIFIED LEAKAGE	1-3
INSERVICE TESTING PROGRAM.....	1-4
OFFSITE DOSE CALCULATION MANUAL (ODCM)	1-4
OPERABLE - OPERABILITY	1-4
OPERATIONAL MODE - MODE	1-4
PHYSICS TESTS.....	1-5
PRESSURE BOUNDARY LEAKAGE	1-5
PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR).....	1-5
PROCESS CONTROL PROGRAM (PCP).....	1-5
PURGE-PURGING	1-5
QUADRANT POWER TILT RATIO	1-5
RATED THERMAL POWER . . .	1-5
REACTOR TRIP SYSTEM RESPONSE TIME	1-6
REPORTABLE EVENT	1-6
SHUTDOWN MARGIN	1-6
SOLIDIFICATION.....	1-6
SOURCE CHECK	1-6
STAGGERED TEST BASIS ..	1-6
THERMAL POWER	1-7
UNIDENTIFIED LEAKAGE ..	1-7
VENTILATION EXHAUST TREATMENT SYSTEM.....	1-7
VENTING	1-7

INDEX

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

SECTION

PAGE

2.1 SAFETY LIMITS

Reactor Core2-1
Reactor Coolant System Pressure2-3

2.2 LIMITING SAFETY SYSTEM SETTINGS

Reactor Trip System Instrumentation Setpoints2-4

BASES

SECTION

PAGE

2.1 SAFETY LIMITS

Reactor CoreB 2-1
Reactor Coolant System PressureB 2-2

2.2 LIMITING SAFETY SYSTEM SETTINGS

Reactor Trip System Instrumentation SetpointsB 2-3

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.0</u> <u>APPLICABILITY</u>	3/4 0-1
<u>3/4.1</u> <u>REACTIVITY CONTROL SYSTEMS</u>	
3/4.1.1 <u>BORATION CONTROL</u>	
Shutdown Margin - $T_{avg} > 200^{\circ}F$	3/4 1-1
Shutdown Margin - $T_{avg} \leq 200^{\circ}F$	3/4 1-3
Moderator Temperature Coefficient	3/4 1-4
Minimum Temperature for Criticality	3/4 1-6
3/4.1.2 <u>BORATION SYSTEMS</u>	
Flow Paths - Shutdown	3/4 1-7
Flow Paths - Operating	3/4 1-8
Charging Pump - Shutdown	3/4 1-9
Charging Pump - Operating	3/4 1-10
Borated Water Sources - Shutdown	3/4 1-11
Borated Water Sources - Operating	3/4 1-12
3/4.1.3 <u>MOVABLE CONTROL ASSEMBLIES</u>	
Group Height	3/4 1-13
Position Indicating Systems - Operating	3/4 1-16
Position Indicating Systems - Shutdown	3/4 1-17
Rod Drop Time	3/4 1-18
Shutdown Rod Insertion Limit	3/4 1-19
Control Rod Insertion Limits	3/4 1-20

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.2</u>	<u>POWER DISTRIBUTION LIMITS</u>
3/4.2.1	AXIAL FLUX DIFFERENCE3/4 2-1
3/4.2.2	HEAT FLUX HOT CHANNEL FACTOR3/4 2-5
3/4.2.3	NUCLEAR ENTHALPY HOT CHANNEL FACTOR..... 3/4 2-9
3/4.2.4	QUADRANT POWER TILT RATIO3/4 2-13
3/4.2.5	DNB PARAMETERS3/4 2-16
<u>3/4.3</u>	<u>INSTRUMENTATION</u>
3/4.3.1	REACTOR TRIP SYSTEM INSTRUMENTATION3/4 3-1
3/4.3.2	ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION3/4 3-14
3/4.3.3	MONITORING INSTRUMENTATION
	Radiation Monitoring Instrumentation3/4 3-38
	Remote Shutdown Instrumentation3/4 3-43
	Accident Monitoring Instrumentation3/4 3-50
	Radioactive Liquid Effluent Monitoring Instrumentation3/4 3-53
	Power Distribution Monitoring System3/4 3-65
3/4.3.4	DELETED

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION	
Startup and Power Operation	3/4 4-1
Hot Standby.....	3/4 4-2
Hot Shutdown	3/4 4-3
Cold Shutdown	3/4 4-4a
3/4.4.2 SAFETY VALVES - SHUTDOWN	3/4 4-5
3/4.4.3 SAFETY VALVES - OPERATING	3/4 4-6
3/4.4.4 PRESSURIZER.....	3/4 4-7
3/4.4.5 RELIEF VALVES.....	3/4 4-8
3/4.4.6 STEAM GENERATOR (SG) TUBE INTEGRITY.....	3/4 4-9
3/4.4.7 REACTOR COOLANT SYSTEM LEAKAGE	
Leakage Detection System	3/4 4-16
Operational Leakage	3/4 4-17
3/4.4.8 DELETED	
3/4.4.9 SPECIFIC ACTIVITY.....	3/4 4-23
3/4.4.10 PRESSURE/TEMPERATURE LIMITS	
Reactor Coolant System	3/4 4-27
Pressurizer	3/4 4-30
Overpressure Protection Systems	3/4 4-31
3/4.4.11 DELETED.....	3/4 4-33
3/4.4.12 DELETED.....	3/4 4-34

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
3/4.5	<u>EMERGENCY CORE COOLING SYSTEMS (ECCS)</u>
3/4.5.1	ACCUMULATORS3/4 5-1
3/4.5.2	ECCS SUBSYSTEMS - $T_{avg} \geq 350^{\circ}F$3/4 5-3
3/4.5.3	ECCS SUBSYSTEMS - $T_{avg} < 350^{\circ}F$3/4 5-7
3/4.5.4	SEAL INJECTION FLOW3/4 5-8a
3/4.5.5	REFUELING WATER STORAGE TANK3/4 5-9
3/4.6	<u>CONTAINMENT SYSTEMS</u>
3/4.6.1	PRIMARY CONTAINMENT
	Containment Integrity3/4 6-1
	Containment Leakage3/4 6-2
	Containment Air Locks3/4 6-4
	Internal Pressure3/4 6-6
	Air Temperature3/4 6-7
	Containment Structural Integrity.....3/4 6-8
	Containment Ventilation System.....3/4 6-9
3/4.6.2	DEPRESSURIZATION AND COOLING SYSTEMS
	Containment Spray System3/4 6-10
	Spray Additive System3/4 6-11
	Containment Cooling System3/4 6-12
3/4.6.3	CONTAINMENT ISOLATION VALVES3/4 6-14

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 TURBINE CYCLE	
Safety Valves.....	3/4 7-1
Auxiliary Feedwater System.....	3/4 7-5
Auxiliary Feed Storage Tank.....	3/4 7-7
Activity.....	3/4 7-8
Main Steam Line Isolation Valves.....	3/4 7-10
3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION.....	3/4 7-11
3/4.7.3 COMPONENT COOLING WATER SYSTEM.....	3/4 7-12
3/4.7.4 SERVICE WATER SYSTEM.....	3/4 7-13
3/4.7.5 FLOOD PROTECTION.....	3/4 7-14
3/4.7.6 CONTROL ROOM EMERGENCY AIR CONDITIONING SYSTEM.....	3/4 7-15
3/4.7.7 AUXILIARY BUILDING VENTILATION SYSTEM.....	3/4 7-18
3/4.7.8 SEALED SOURCE CONTAMINATION.....	3/4 7-21
3/4.7.9 SNUBBERS.....	3/4 7-23
3/4.7.10 CHILLED WATER SYSTEM - AUXILIARY BUILDING SUBSYSTEM.....	3/4 7-28
3/4.7.11 FUEL STORAGE POOL BORON CONCENTRATION.....	3/4 7-30
3/4.7.12 FUEL ASSEMBLY STORAGE IN THE SPENT FUEL POOL.....	3/4 7-31
3/4.7.13 MAIN FEEDWATER ISOLATION VALVES (FIVs), MAIN FEEDWATER REGULATING VALVES (FRVs), FRV BYPASS VALVES, AND STEAM GENERATOR FEEDWATER PUMP (SGFP) TURBINE STEAM STOP VALVES	3/4 7-33

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 A. C. SOURCES	
Operating	3/4 8-1
Shutdown	3/4 8-7a
3/4.8.2 ONSITE POWER DISTRIBUTION SYSTEMS	
A.C. Distribution - Operating	3/4 8-8
A.C. Distribution - Shutdown	3/4 8-9
125-Volt D.C. Distribution - Operating	3/4 8-10
125-Volt D.C. Distribution - Shutdown	3/4 8-12
28-Volt D.C. Distribution - Operating	3/4 8-13
28-Volt D.C. Distribution - Shutdown	3/4 8-15
3/4.8.3 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES	
Containment Penetration Conductor Overcurrent Protective Devices	3/4 8-16

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.9 REFUELING OPERATIONS</u>	
3/4.9.1 BORON CONCENTRATION	3/4 9-1
3/4.9.2.1 UNBORATED WATER SOURCE ISOLATION VALVES	3/4 9-2a
3/4.9.2.2 INSTRUMENTATION	3/4 9-2b
3/4.9.3 DELETED	3/4 9-3
3/4.9.4 CONTAINMENT BUILDING PENETRATIONS	3/4 9-4
3/4.9.5 DELETED	3/4 9-5
3/4.9.6 DELETED	3/4 9-6
3/4.9.7 DELETED	3/4 9-7
3/4.9.8 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION	
All Water Levels	3/4 9-8
Low Water Level	3/4 9-9
3/4.9.9 DELETED	
3/4.9.10 WATER LEVEL - REACTOR VESSEL	3/4 9-11
3/4.9.11 STORAGE POOL WATER LEVEL	3/4 9-12
3/4.9.12 DELETED	3/4 9-13
<u>3/4.10 SPECIAL TEST EXCEPTIONS</u>	
3/4.10.1 SHUTDOWN MARGIN	3/4 10-1
3/4.10.2 GROUP HEIGHT, INSERTION AND POWER DISTRIBUTION LIMITS	3/4 10-2
3/4.10.3 PHYSICS TESTS	3/4 10-4
3/4.10.4 NO FLOW TESTS	3/4 10-5

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.11 RADIOACTIVE EFFLUENTS</u>	
3/4.11.1 LIQUID EFFLUENTS	
Liquid Holdup Tanks	3/4 11-7
3/4.11.2 GASEOUS EFFLUENTS	
Explosive Gas Mixture	3/4 11-15
3/4.11.3 Deleted	3/4 11-17
3/4.11.4 Deleted	3/4 11-18
<u>3/4.12 Deleted</u>	

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.0 APPLICABILITY</u>	B 3/4 0-1
<u>3/4.1 REACTIVITY CONTROL SYSTEMS</u>	
3/4.1.1 BORATION CONTROL	B 3/4 1-1
3/4.1.2 BORATION SYSTEMS	B 3/4 1-3
3/4.1.3 MOVABLE CONTROL ASSEMBLIES	B 3/4 1-4
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1 AXIAL FLUX DIFFERENCE	B 3/4 2-1
3/4.2.2 HEAT FLUX AND NUCLEAR ENTHALPY and	
3/4.2.3 HOT CHANNEL AND RADIAL PEAKING FACTOR.....	B 3/4 2-4
3/4.2.4 QUADRANT POWER TILT RATIO	B 3/4 2-5
3/4.2.5 DNB PARAMETERS	B 3/4 2-6

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1 PROTECTIVE AND AND	
3/4.3.2 ENGINEERED SAFETY FEATURES (ESF) INSTRUMENTATION	B 3/4 3-1
3/4.3.3 MONITORING INSTRUMENTATION.....	B 3/4 3-1c
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION	B 3/4 4-1
3/4.4.2 and SAFETY VALVES.....	B 3/4 4-2
3/4.4.3	
3/4.4.4 PRESSURIZER	B 3/4 4-2
3/4.4.5 RELIEF VALVES	B 3/4 4-2
3/4.4.6 STEAM GENERATOR (SG) TUBE INTEGRITY	B 3/4 4-3
3/4.4.7 REACTOR COOLANT SYSTEM LEAKAGE	B 3/4 4-4
3/4.4.8 DELETED	
3/4.4.9 SPECIFIC ACTIVITY	B 3/4 4-6
3/4.4.10 PRESSURE/TEMPERATURE LIMITS.....	B 3/4 4-7
3/4.4.11 DELETED.....	B 3/4 4-18
3/4.4.12 DELETED.....	B 3/4 4-18

INDEX

BASES

=====

=

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.5</u> <u>EMERGENCY CORE COOLING SYSTEMS (ECCS)</u>	
3/4.5.1 ACCUMULATORS	B 3/4 5-1
3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS	B 3/4 5-1
3/4.5.4 SEAL INJECTION FLOW	B 3/4 5-2
3/4.5.5 REFUELING WATER STORAGE TANK (RWST)	B 3/4 5-3
<u>3/4.6</u> <u>CONTAINMENT SYSTEMS</u>	
3/4.6.1 PRIMARY CONTAINMENT	B 3/4 6-1
3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS	B 3/4 6-3
3/4.6.3 CONTAINMENT ISOLATION VALVES	B 3/4 6-4

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 TURBINE CYCLE.....	B 3/4 7-1
3/4.7.1 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION.....	B 3/4 7-4
3/4.7.3 COMPONENT COOLING WATER SYSTEM.....	B 3/4 7-4
3/4.7.4 SERVICE WATER SYSTEM.....	B 3/4 7-4
3/4.7.5 FLOOD PROTECTION.....	B 3/4 7-5
3/4.7.6 CONTROL ROOM EMERGENCY AIR CONDITIONING SYSTEM.....	B 3/4 7-5
3/4.7.7 AUXILIARY BUILDING EXHAUST AIR FILTRATION SYSTEM.....	B 3/4 7-5c
3/4.7.8 SEALED SOURCE CONTAMINATION.....	B 3/4 7-5c
3/4.7.9 SNUBBERS.....	B 3/4 7-6
3/4.7.10 CHILLED WATER SYSTEM AUXILIARY BUILDING SYSTEM.....	B 3/4 7-8
3/4.7.11 FUEL STORAGE POOL BORON CONCENTRATION.....	B 3/4 7-9
3/4.7.12 FUEL ASSEMBLY STORAGE IN THE SPENT FUEL POOL.....	B 3/4 7-12
3/4.7.13 MAIN FEEDWATER ISOLATION VALVES (FIVs), MAIN FEEDWATER REGULATING VALVES (FRVs), FRV BYPASS VALVES, AND STEAM GENERATOR FEEDWATER PUMP (SGFP) TURBINE STEAM STOP VALVES	B 3/4 7-13
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 A. C. SOURCES.....	B 3/4 8-1
3/4.8.2 ONSITE POWER DISTRIBUTION SYSTEMS.....	B 3/4 8-1
3/4.8.3 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES.....	B 3/4 8-4

INDEX

BASES

=====

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.9 REFUELING OPERATIONS</u>	
3/4.9.1 BORON CONCENTRATION	B 3/4 9-1
3/4.9.2.1 UNBORATED WATER SOURCE ISOLATION VALVES	B 3/4 9-1b
3/4.9.2.2 INSTRUMENTATION	B 3/4 9-1b
3/4.9.3 DELETED	B 3/4 9-1c
3/4.9.4 CONTAINMENT BUILDING PENETRATIONS	B 3/4 9-1d
3/4.9.5 COMMUNICATIONS	B 3/4 9-3
3/4.9.6 MANIPULATOR CRANE	B 3/4 9-3
3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE BUILDING.....	B 3/4 9-3
3/4.9.8 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION...	B 3/4 9-3
3/4.9.9 CONTAINMENT PURGE AND PRESSURE-VACUUM RELIEF ISOLATION SYSTEM	B 3/4 9-4
3/4.9.10 WATER LEVEL - REACTOR VESSEL And AND	
3/4.9.11 STORAGE POOL	B 3/4 9-4
3/4.9.12 DELETED	B 3/4 9-4
<u>3/4.10 SPECIAL TEST EXCEPTIONS</u>	
3/4.10.1 SHUTDOWN MARGIN	B 3/4 10-1
3/4.10.2 GROUP HEIGHT, INSERTION AND POWER DISTRIBUTION LIMITS	B 3/4 10-1
3/4.10.3 PHYSICS TESTS	B 3/4 10-1
3/4.10.4 NO FLOW TESTS	B 3/4 10-1

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.11</u> <u>RADIOACTIVE EFFLUENTS</u>	
3/4.11.1 LIQUID EFFLUENTS	B 3/4 11-1
3/4.11.2 GASEOUS EFFLUENTS	B 3/4 11-3
3/4.11.3 Deleted	B 3/4 11-6
3/4.11.4 Deleted	B 3/4 11-7
<u>3/4.12</u> <u>Deleted</u>	

INDEX

DESIGN FEATURES

=====

<u>SECTION</u>	<u>PAGE</u>
<u>5.1 SITE LOCATION</u>	5-1
<u>5.2 CONTAINMENT</u>	
Configuration	5-1
Design Pressure and Temperature	5-4
<u>5.3 REACTOR CORE</u>	
Fuel Assemblies	5-4
Control Rod Assemblies	5-4
<u>5.4 REACTOR COOLANT SYSTEM</u>	
Design Pressure and Temperature	5-4
<u>5.5 DELETED</u>	5-5
<u>5.6 FUEL STORAGE</u>	
Criticality	5-5
Drainage	5-5b
Capacity	5-5b
<u>5.7 COMPONENT CYCLIC OR TRANSIENT LIMIT</u>	5-5b

INDEX

ADMINISTRATIVE CONTROLS

=====

<u>SECTION</u>	<u>PAGE</u>
<u>6.1 RESPONSIBILITY</u>	6-1
 <u>6.2 ORGANIZATION</u>	
Onsite and Office Organizations	6-1
Facility Staff	6-1
Shift Technical Advisor	6-7
 <u>6.3 FACILITY STAFF QUALIFICATIONS</u>	6-7
 <u>6.4 DELETED</u>	6-7
 <u>6.5 REVIEW AND AUDIT (THIS SECTION DELETED)</u>	6-8
 <u>6.6 REPORTABLE EVENT ACTION</u>	6-16
 <u>6.7 SAFETY LIMIT VIOLATION</u>	6-16
 <u>6.8 PROCEDURES AND PROGRAMS</u>	6-17
 <u>6.9 REPORTING REQUIREMENTS</u>	
6.9.1 ROUTINE REPORTS	6-20
6.9.2 SPECIAL REPORTS	6-24C
 <u>6.10 RECORD RETENTION</u>	6-25
 <u>6.11 RADIATION PROTECTION PROGRAM</u>	6-26
 <u>6.12 HIGH RADIATION AREA</u>	6-27
 <u>6.13 PROCESS CONTROL PROGRAM (PCP)</u>	6-28
 <u>6.14 OFFSITE DOSE CALCULATION MANUAL (ODCM)</u>	6-29
 <u>6.15 MAJOR CHANGES TO RADIOACTIVE LIQUID, GASEOUS AND SOLID WASTE TREATMENT SYSTEMS</u>	6-29
 <u>6.16 TECHNICAL SPECIFICATION (TS) BASES CONTROL PROGRAM</u>	6-30
 <u>6.17 CONTROL ROOM ENVELOPE HABITABILITY PROGRAM</u>	6-31

SECTION 1.0
DEFINITIONS

1.0 DEFINITIONS

DEFINED TERMS

1.1 The DEFINED TERMS of this section appear in capitalized type and are applicable throughout these Technical Specifications.

ACTION

1.2 ACTION shall be that part of a specification which prescribes remedial measures required under designated conditions.

AXIAL FLUX DIFFERENCE

1.3 AXIAL FLUX DIFFERENCE shall be the difference in normalized flux signals between the top and bottom halves of a two section excore neutron detector.

CHANNEL CALIBRATION

1.4 A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds with the necessary range and accuracy to known values of the parameter that the channel monitors. The CHANNEL CALIBRATION shall encompass the entire channel, including the required sensor, alarm, display, and trip functions, and shall include the CHANNEL FUNCTIONAL TEST. Calibration of instrument channels with resistance temperature detector (RTD) or thermocouple sensors may consist of an in-place qualitative assessment of sensor behavior and normal calibration of the remaining adjustable devices in the channel. Whenever an RTD or thermocouple sensing element is replaced, the next required CHANNEL CALIBRATION shall include an in-place cross calibration that compares the other sensing elements with the recently installed sensing element. The CHANNEL CALIBRATION may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.

CHANNEL CHECK

1.5 A CHANNEL CHECK shall be the qualitative assessment of channel behavior during operation by observation. This determination shall include, where possible, comparison of the channel indication and/or status with other indications and/or status derived from independent instrument channels measuring the same parameter.

CHANNEL FUNCTIONAL TEST

1.6 A CHANNEL FUNCTIONAL TEST shall be the injection of a simulated signal into the channel as close to the primary sensor as practicable to verify OPERABILITY including alarm and/or trip functions. The CHANNEL FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps, and each step must be performed within the Frequency in the Surveillance Frequency Control Program for the devices included in the step.

DEFINITIONS

CONTAINMENT INTEGRITY

1.7 CONTAINMENT INTEGRITY shall exist when:

- 1.7.1 All penetrations required to be closed during accident conditions are either:
 - a. Capable of being closed by an OPERABLE containment automatic isolation valve system, or
 - b. Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except for valves that are opened under administrative control as permitted by Specification 3.6.3.
- 1.7.2 All equipment hatches are closed and sealed,
- 1.7.3 Each air lock is OPERABLE pursuant to Specification 3.6.1.3,
- 1.7.4 The containment leakage rates are within the limits of Specification 3.6.1.2, and
- 1.7.5 The sealing mechanism associated with each penetration (e.g., welds, bellows or O-rings) is OPERABLE.

CORE ALTERATION

1.8.1 CORE ALTERATION shall be the movement of any fuel, sources, or reactivity control components, within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATIONS shall not preclude completion of movement of a component to a safe conservative position.

CORE OPERATING LIMITS REPORT

1.9 The CORE OPERATING LIMITS REPORT (COLR) is the unit-specific document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9.1.9. Unit operation within these operating limits is addressed in individual specifications.

DOSE EQUIVALENT I-131

1.10 DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microcuries per gram) that alone would produce the same dose when inhaled as the combined activities of iodine isotopes I-131, I-132, I-133, I-134, and I-135 actually present. The determination of DOSE EQUIVALENT I-131 shall be performed using the "Thyroid" Committed Dose Equivalent (CDE) dose conversion factors from Table 2.1 of EPA Federal Guidance Report No. 11, 1988, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion and Ingestion."

DEFINITIONS

REACTOR TRIP SYSTEM RESPONSE TIME

1.26 The REACTOR TRIP SYSTEM RESPONSE TIME shall be the time interval from when the monitored parameter exceeds its trip setpoint at the channel sensor until loss of stationary gripper coil voltage.

REPORTABLE EVENT

1.27 A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 to 10CFR Part 50.

SHUTDOWN MARGIN

1.28 SHUTDOWN MARGIN shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming all full length rod cluster assemblies (shutdown and control) are fully inserted except for the single rod cluster assembly of highest reactivity worth which is assumed to be FULLY WITHDRAWN.

SITE BOUNDARY

1.29 The SITE BOUNDARY shall be that line beyond which the land is not owned, leased, or otherwise controlled by the licensee, as shown in Figure 5.1-3, and which defines the exclusion area as shown in Figure 5.1-1.

SOLIDIFICATION

1.30 Not Used

SOURCE CHECK

1.31 SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to either (a) an external source of increased radioactivity, or (b) an internal source of radioactivity (keep-alive source), or (c) an equivalent electronic source check .

STAGGERED TEST BASIS

1.32 A STAGGERED TEST BASIS shall consist of:

- a. A test schedule for (n) systems, subsystems, trains, or other designated components obtained by dividing the specified test interval into (n) equal subintervals.

DEFINITIONS

DOSE EQUIVALENT XE-133

1.11 DOSE EQUIVALENT XE-133 shall be that concentration of XE-133 (microcuries per gram) that alone would produce the same acute dose to the whole body as the combined activities of noble gas nuclides Kr-85m, Kr-85, Kr-87, Kr-88, Xe-131m, Xe-133m, Xe-133, Xe-135m, Xe-135 and Xe-138 actually present. If a specific noble gas nuclide is not detected, it should be assumed to be present at a minimum detectable activity. The determination of DOSE EQUIVALENT XE-133 shall be performed using effective dose conversion factors for air submersion listed in Table III.1 of EPA Federal Guidance Report No. 12, 1993, "External Exposure to Radionuclides in Air, Water and Soil."

ENGINEERED SAFETY FEATURE RESPONSE TIME

1.12 The ENGINEERED SAFETY FEATURE RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its actuation setpoint at the channel sensor until the ESF equipment is capable of performing its safety function (i.e., the valves travel to their required positions, pump discharge pressures reach their required values, etc.). Times shall include diesel generator starting and sequence loading delays where applicable. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured. In lieu of measurement, response time may be verified for selected components provided that the components and methodology for verification have been previously reviewed and approved by the NRC, or the components have been evaluated in accordance with an NRC approved methodology.

FREQUENCY NOTATION

1.13 The FREQUENCY NOTATION specified for the performance of Surveillance Requirements shall correspond to the intervals defined in Table 1.2.

FULLY WITHDRAWN

1.13a FULLY WITHDRAWN shall be the condition where control and/or shutdown banks are at a position which is within the interval of 222 to 230 steps withdrawn, inclusive. FULLY WITHDRAWN will be specified in the current reload analysis.

GASEOUS RADWASTE TREATMENT SYSTEM

1.14 A GASEOUS RADWASTE TREATMENT SYSTEM is any system designed and installed to reduce radioactive gaseous effluents by collecting primary coolant system offgases from the primary system and providing for delay or holdup for the purpose of reducing the total radioactivity prior to release to the environment.

IDENTIFIED LEAKAGE

1.15 IDENTIFIED LEAKAGE shall be:

- a. Leakage (except Reactor Coolant Pump Seal Water Injection) into closed systems, such as pump seal or valve packing leaks that are captured and conducted to a sump or collecting tank, or

DEFINITIONS

- b. Leakage into the containment atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be PRESSURE BOUNDARY LEAKAGE, or
- c. Reactor coolant system leakage through a steam generator to the secondary system (primary-to-secondary leakage).

INSERVICE TESTING PROGRAM

1.15.1 The INSERVICE TESTING PROGRAM is the licensee program that fulfills the requirements of 10 CFR 50.55a(f).

1.16 Not Used

OFFSITE DOSE CALCULATION MANUAL (ODCM)

1.17 The OFFSITE DOSE CALCULATION MANUAL (ODCM) shall contain the methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring Alarm/Trip Setpoints, and in the conduct of the Environmental Radiological Monitoring Program. The ODCM shall also contain (1) the Radioactive Effluent controls and Radiological Environmental Monitoring programs required by Section 6.8.4 and (2) descriptions of the information that should be included in the Annual Radiological Environmental Operating and Annual Radioactive Effluent Release Reports required by Specifications 6.9.1.7 and 6.9.1.8 respectively.

OPERABLE - OPERABILITY

1.18 A system, subsystem, train, component or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s), and when all necessary attendant instrumentation, controls, normal or emergency electrical power source, cooling and seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component or device to perform its specified safety function(s) are also capable of performing their related support function(s).

OPERATIONAL MODE - MODE

1.19 An OPERATIONAL MODE (i.e., MODE) shall correspond to any one inclusive combination of core reactivity condition, power level and average reactor coolant temperature specified in Table 1.1.

DEFINITIONS

PHYSICS TESTS

1.20 PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation and 1) described in Chapter 14 of the Updated FSAR, 2) authorized under the provisions of 10CFR50.59, or 3) otherwise by the Commission.

PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)

1.20a The PTLR is the unit specific document that provides the reactor vessel pressure and temperature limits, including heatup and cooldown rates, and the Overpressure Protection System setpoint and enable temperature, for the current reactor vessel fluence period. The pressure and temperature limits shall be determined for each fluence period in accordance with Technical Specification Section 6.9.1.11.

PRESSURE BOUNDARY LEAKAGE

1.21 PRESSURE BOUNDARY LEAKAGE shall be leakage (except primary-to-secondary leakage) through a non-isolable fault in a Reactor Coolant System component body, pipe wall or vessel wall.

PROCESS CONTROL PROGRAM (PCP)

1.22 The PROCESS CONTROL PROGRAM (PCP) shall contain the current formulas, sampling, analyses, test, and determinations to be made to ensure that processing and packaging of solid radioactive wastes based on demonstrated processing of actual or simulated wet solid wastes will be accomplished in such a way as to assure compliance with 10 CFR Parts 20, 61, and 71, State regulations, burial ground requirements, and other requirements governing the disposal of radioactive waste.

PURGE - PURGING

1.23 PURGE or PURGING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration, or other operating condition, in such a manner that replacement air or gas is required to purify the confinement.

QUADRANT POWER TILT RATIO

1.24 QUADRANT POWER TILT RATIO shall be the ratio of the maximum upper excore detector calibrated output to the average of the upper excore detector calibrated outputs, or the ratio of the maximum lower excore detector calibrated output to the average of the lower excore detector calibrated outputs, whichever is greater. With one excore detector inoperable, the remaining three detectors shall be used for computing the average.

RATED THERMAL POWER

1.25 RATED THERMAL POWER shall be a total reactor core heat transfer rate to the reactor coolant of 3459 MWt.

DEFINITIONS

REACTOR TRIP SYSTEM RESPONSE TIME

1.26 The REACTOR TRIP SYSTEM RESPONSE TIME shall be the time interval from when the monitored parameter exceeds its RTS trip setpoint at the channel sensor until loss of stationary gripper coil voltage. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured. In lieu of measurement, response time may be verified for selected components provided that the components and methodology for verification have been previously reviewed and approved by the NRC, or the components have been evaluated in accordance with an NRC approved methodology.

REPORTABLE EVENT

1.27 A REPORTABLE EVENT shall be any of those conditions specified in Section 50.73 to 10CFR Part 50.

SHUTDOWN MARGIN

1.28 SHUTDOWN MARGIN shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming all full length rod cluster assemblies (shutdown and control) are fully inserted except for the single rod cluster assembly of highest reactivity worth which is assumed to be FULLY WITHDRAWN.

1.29 Not Used

SOLIDIFICATION

1.30 Not Used

SOURCE CHECK

1.31 SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to either (a) an external source of increased radioactivity, or (b) an internal source of radioactivity (keep-alive source), or (c) an equivalent electronic source check.

STAGGERED TEST BASIS

1.32 A STAGGERED TEST BASIS shall consist of:

- a. A test schedule for (n) systems, subsystems, trains, or other designated components obtained by dividing the specified test interval into (n) equal subintervals.

DEFINITIONS

- b. The testing of one system, subsystem, train, or other designated component at the beginning of each subinterval.

THERMAL POWER

1.33 THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

UNIDENTIFIED LEAKAGE

1.34 UNIDENTIFIED LEAKAGE shall be all leakage (except Reactor Coolant Pump Seal Water Injection) which is not IDENTIFIED LEAKAGE.

1.35 Not Used

VENTILATION EXHAUST TREATMENT SYSTEM

1.36 A VENTILATION EXHAUST TREATMENT SYSTEM shall be any system designed and installed to reduce gaseous radioiodine and radioactive material in particulate form in effluents by passing ventilation or vent exhaust gases through charcoal adsorbers and/or HEPA filters for the purpose of removing iodines or particulates from the gaseous exhaust stream prior to the release to the environment (such a system is not considered to have any effect on noble gas effluents). Engineered Safety Feature (ESF) atmospheric cleanup systems are not considered to be VENTILATION EXHAUST TREATMENT SYSTEM components.

VENTING

1.37 VENTING shall be the controlled process of discharging air or gas from a confinement to maintain temperature, pressure, humidity, concentration, or other operating condition, in such a manner that replacement air or gas is not provided or required during VENTING. Vent, used in system names, does not imply a VENTING process.

DEFINITIONS

TABLE 1.1
OPERATIONAL MODES

<u>MODE</u>	<u>REACTIVITY CONDITION, K_{eff}</u>	<u>THERMAL POWER*</u>	<u>AVERAGE COOLANT TEMPERATURE</u>
1. POWER OPERATION	≥ 0.99	$> 5\%$	$\geq 350^\circ\text{F}$
2. STARTUP	≥ 0.99	$\leq 5\%$	$\geq 350^\circ\text{F}$
3. HOT STANDBY	< 0.99	0	$\geq 350^\circ\text{F}$
4. HOT SHUTDOWN	< 0.99	0	$350^\circ\text{F} > T_{avg}$ $> 200^\circ\text{F}$
5. COLD SHUTDOWN	< 0.99	0	$\leq 200^\circ\text{F}$
6. REFUELING**	≤ 0.95	0	$\leq 140^\circ\text{F}$

* Excluding decay heat.

** Fuel in the reactor vessel with the vessel head closure bolts less than fully tensioned or with the head removed.

DEFINITIONS

TABLE 1.2
FREQUENCY NOTATION

<u>NOTATION</u>	<u>FREQUENCY</u>
S	At least once per 12 hours.
D	At least once per 24 hours.
W	At least once per 7 days.
M	At least once per 31 days.
Q	At least once per 92 days.
SA	At least once per 6 months.
R	At least once per 18 months.
S/U	Prior to each reactor startup.
P	Prior to each release.
N.A.	Not applicable.