

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SAFETY VALVES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2 A minimum of one pressurizer code safety valve shall be OPERABLE* with a lift setting of 2485 psig \pm 3%.**,***

APPLICABILITY: Mode 4 and 5

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE RHR loop into operation in the shutdown cooling mode.

SURVEILLANCE REQUIREMENTS

4.4.2.1 No additional Surveillance Requirements other than those required by the INSERVICE TESTING PROGRAM.

* While in Mode 5, an equivalent size vent pathway may be used provided that the vent pathway is not isolated or sealed.

** The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

*** Following testing the lift setting shall be reset to within \pm 1%.