

## REACTOR COOLANT SYSTEM

### 3/4.4.4 PRESSURIZER

#### LIMITING CONDITION FOR OPERATION

---

3.4.4 The pressurizer shall be OPERABLE with a water volume of less than or equal to 1650 cubic feet (92% indicated level), and at least two groups of pressurizer heaters each having a capacity of  $\geq 150$  kw and capable of being powered from an emergency power supply.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With the pressurizer inoperable due to an inoperable emergency power supply to the pressurizer heaters either restore the inoperable emergency power supply within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With the pressurizer otherwise inoperable, be in at least HOT STANDBY with the reactor trip breakers open within 6 hours and in HOT SHUTDOWN within the following 6 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.4.4.1 The pressurizer water volume shall be determined to be within its limit in accordance with the Surveillance Frequency Control Program.

4.4.4.2 The capacity of each of the above required groups of pressurizer heaters shall be verified by measuring circuit current in accordance with the Surveillance Frequency Control Program.

4.4.4.3 The emergency power supply for the pressurizer heaters shall be demonstrated OPERABLE in accordance with the Surveillance Frequency Control Program by manually transferring power from the normal to the emergency power supply and energizing the heaters.