

## PLANT SYSTEMS

### 3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION

#### LIMITING CONDITION FOR OPERATION

---

3.7.2 The temperatures of both the primary and secondary coolants in the steam generators shall be greater than 70°F when the pressure of either coolant in the steam generator is greater than 200 psig.

APPLICABILITY: At all times.

#### ACTION:

With the requirements of the above specification not satisfied:

- a. Reduce the steam generator pressure of the applicable side to less than or equal to 200 psig within 30 minutes, and
- b. Perform an engineering evaluation to determine the effect of the overpressurization on the structural integrity of the steam generator. Determine that the steam generator remains acceptable for continued operation prior to increasing its temperatures above 200°F.

#### SURVEILLANCE REQUIREMENTS

---

4.7.2 The pressure in each side of the steam generator shall be determined to be less than 200 psig in accordance with the Surveillance Frequency Control Program when the temperature of either the primary or secondary coolant is less than 70°F.