3/4.7.5 FLOOD PROTECTION

LIMITING CONDITION FOR OPERATION

3.7.5 Flood protection shall be provided for all safety related systems, components and structures when the water level of the Delaware River exceeds 10.5' Mean Sea Level USGS datum, at the service water intake structure.

APPLICABILITY: At all times.

ACTION:

a. With the water level at the service water intake structure above elevation 10.5' Mean Sea Level USGS datum, close all watertight doors within 2 hours.

b. With the water level at the service water intake structure above elevation 11.5' Mean Sea Level USGS datum, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.5 The water level at the service water intake structure shall be determined to be within the limits by:

a. Measurement in accordance with the Surveillance Frequency Control Program when the water level is below elevation 10.5' Mean Sea Level USGS datum, and

b. Measurement in accordance with the Surveillance Frequency Control Program when the water level is equal to or above elevation 10.5' Mean Sea Level USGS datum.